



BOX CULVERT
TYPICAL SECTION

General Notes

1. CONCRETE SHALL BE 5000 PSI MINIMUM
2. WELDED WIRE IN ACCORDANCE WITH ASTM A497
3. ALL PRECAST ELEMENTS SHALL MEET ASTM-C1433
4. A,B,C,D LENGTH VARIES PER SPECIFIED DRAWING
5. JOINT & JOINT SEALANT MATERIALS SHALL MEET ASTM C990

MANHOLE CASTINGS
FRANKLIN PIPE
STEEL PIPE
GEOTEXTILE FABRICS
EROSION CONTROL

MID-ATLANTIC DRAINAGE, INC

1124 WHITE OAK LANE
GALLIWAY'S FERRY, SC 29944
(843) 336-4200

CATCH BASINS
CONCRETE
MANHOLE
CAST IRON GRATES & FRAMES

P. O. BOX 398
CONWAY, SC 29543
(843) 324-0588

BOX CULVERT

FILE NAME: BC001.DWG	Sheet
DATE: 02.08.2010	1
DRAWN BY: JSW	